

Warranty referred to in Policy No.

WARRANTED that Regulations
(as printed below) are strictly observed throughout the currency of the Policy.

REGULATIONS:

PART I.—FILM PROJECTION AND RE-WINDING ROOMS

1. CONSTRUCTION.

- (a) The projection machine room shall be built outside the auditorium and shall be of sufficient dimensions to allow the operators to work freely.
- (b) It must be substantially constructed of fire-resisting material throughout and any floor covering must also be fire-resisting.
- (c) The wall dividing the room from the auditorium shall be not less than 6 inches (15 cm) thick.
- (d) The entrance must be fitted with a substantial close-fitting, self-closing door which shall open outwards. In cases where access to the room is by a staircase, a platform shall be provided at the top which must be of sufficient dimensions to permit the free handling of fire extinguishing appliances.

2. COMMUNICATION WITH THE AUDITORIUM.

- (a) The only openings permissible in the wall dividing the projection room from the auditorium are the "ports" which shall not be greater in size or more in number than is necessary for effective projection and observation.
- (b) All "port" openings must be fitted with glass windows securely fixed in incombustible material and, in addition, close-fitting steel shutters within fixed metal frames on the machine room side of the wall.
- (c) These steel shutters shall be installed in such a way as to enable them to be released both individually and also simultaneously from a convenient position at the entrance to the room. They shall be kept closed during all non-working hours.

3. HANDLING OF FILMS.

- (a) The re-winding of all films must be done in a separate room which, as regards, construction and communication with the auditorium, shall conform to the foregoing Regulations. Any communication with the projection room shall be provided with a close-fitting self closing iron door or shutter.
- (b) No films other than those intended for current programmes shall be kept in the operating and/or re-winding rooms, and when not in use all films must be stored in closed substantial metal containers. No films whatsoever shall be kept in any other part of the building to which this insurance applies, except in the film store specially provided for the purpose.

4. ELECTRICAL INSTALLATION.

- (a) All wiring must be protected by metal conduit and the electrical installation shall conform in all respects to the Regulations for the electrical equipment of buildings issued by the Institute of Electrical Engineers.
- (b) All Switches and fuses (and connections thereto) must be totally enclosed and iron clad and Electric Lamps and all resistances so protected as to avoid the possibility of their coming into contact with films or other combustible material. Resistances connected with auditorium of stage lighting shall not be located in the projection or re-winding rooms.
- (c) The use of flexible conductors shall be permitted only where they are essential.

5. VENTILATION.

Both the projection and re-winding rooms must have adequate means of ventilation, with sufficient inlets and outlets to ensure a constant supply of air. The inlets and outlets shall communicate directly with the open air.

6. FIRE EXTINGUISHING APPLIANCES.

The following minimum equipment must be installed:—

- (a) Within each projection and re-winding room.
 1. Two 1/2 Gallon (2.25 lit) or 4 Qts. (4.50 lit) Size Special Liquid Chemical Extinguishers.
 2. One bucket of sand.
 3. An asbestos blanket or an ordinary wet blanket with a bucket of water.
- (b) Immediately outside the rooms
Two 1/2 Gallon (2.25 lit) or 4 Qts. (4.50 lit) Size Special Liquid Chemical Extinguishers.

7. GENERAL.

- (a) There shall be not less than two operators present during any exhibition.
- (b) Suitable measures shall be taken to prevent unauthorised persons from obtaining access to the projection and re-winding rooms.
- (c) Smoking within these rooms shall be absolutely forbidden at all times.
- (d) The room shall be kept clean and tidy and nothing shall be stored in them (other than as provided for in para 3 (b) above except necessary spare equipment and then only in a steel cabinet.
- (e) A key must be retained on the premises so that admission may be gained to the projection room and re-winding room at all times.
- (f) The Card of Regulations issued by the Association for the purpose shall be framed and hung in the Projection Room.

N.B.—In cases where operators are unable to read English a translation in a language known to them must also be exhibited.

- (g) During the currency of this policy no stage performance involving the use of any scenery shall be given in the building for which this insurance applies, and no scenery, shall be stored anywhere in the building.

PART II.—AUDITORIUM.

8. Provision shall be made for the carrying out of examination of the auditorium for smouldering matches, tobacco or other material at the close of each day's performance and signed reports shall be made thereon daily by the employee or employees detailed for the examination. Such reports to be checked at least weekly by the management.

N.B.—Smoking within the auditorium or on the stage of premises situated in Karachi shall be absolutely forbidden at all times.

8.A. EXTRA HAZARDS:

- (a) No false ceiling of combustible material (cellotex, compressed paper, card-board and the like) and/or presence of timber construction in the roof.
- (b) No wooden stage and/or Flies
- (c) No framework of seating constructed of wood or other combustible material (i.e. metal framed seats would not be penalized even although the seat upholstery may be combustible material).
- (d) No balconies of inferior construction like wood or other combustible material.